The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.
Send Contractor Inquiries via email to d8_pbi@dot.ca.gov
The mailing address is 655 2nd Street, San Bernardino, CA 92402.
Phone (909) 383-5961
Fax (909) 383-6739.
All inquiries must include the contract number.

08-497504

Inquiry No.	Inquiry/Response
1.0	Question_1: When will the cross sections be available for our use? Response: Cross sections for this project will be available starting 05/17/2010. If interested please contact the above listed numbers to obtain a copy.
2.0	Special_Provisions_Specific: HOT MIX ASPHALT CONCRETE Question_2: This item does not reference type A or B. is there an error with the quantities? The quantity indicates 3.4 tons. I just want to make sure that this item is not in error. Response: Quantity of 3.4 Tons refers to Hot Mix Asphalt (Type A), please refer to the Standard Specification (SSP) of Hot Mix Asphalt for more information.
3.0	Question_3: Bid item description for item 90-Concrete Barrier (Type 60c) refers to Type 60C. Please provide profile or barrier elevations to calculate the variable height of the barrier. Response: Pending.
4.0	Question_4: Plan sheets and typical sections refer to Type 60 Barrier, which has a constant height. Should bid item #90 be for Type 60 barrier instead of Type 60C barrier? Response: Pending.
5.0	Question_5: Question_1: You have not provided contour grading plans with the project plans. Are there cross sections available for this project? Response: No contour grading plans. There are X-sections and slope stake listing available, If interested please contact the above listed numbers to obtain a copy.
6.0	Question_6: You have not provided staging plans with the project plans. Does that mean you can do the entire job at one time? Response: Please see Traffic Handling plans, Temporary K -rail are used to separate the

	traffic and construction area.
7.0	Question_7: E-3 (SH 246) is missing out of bid set. Please clarify. Response: Pending.
8.0	Question_8: Can you please check quantities for the retaining wall. Bid item number 55. I find there is a discrepancy of 459 cy that appears to be in the type 1 wall Response: Pending.
9.0	Question_9: can you please re-calculate your quantity for the retaining wall (Type 1). and adjust the bid item accordingly? Response: Pending.