

The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.

Send Contractor Inquiries via email to d8_pbi@dot.ca.gov

The mailing address is 655 2nd Street, San Bernardino, CA 92402.

Phone (909) 829-3331

Fax (909) 829-3347.

All inquiries must include the contract number.

08-0N1404	
Inquiry No.	Inquiry/Response
1.0	<p>Question_1.0: Section 12-1.01 States This work includes the construction of 3,000 gallon emulsion tanks and concrete slabs at seven locations and removing existing emulsion tank and concrete slab at six locations as shown on the plans. The plans only show 5 locations</p> <p>Response: Five locations is correct.</p>
2.0	<p>Question_2.0: Will Caltrans be disposing of the existing emulsion in the tanks? if not will caltrans drain and clean the existing tanks ? if not how much emulsion can the contractor expect to deal with ?</p> <p>Response: Emulsion tanks will be drained. Contractor is responsible for disposal.</p>