

The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.

Send Contractor Inquiries via email to d8_pbi@dot.ca.gov

The mailing address is 655 2nd Street, San Bernardino, CA 92402.

Phone (909) 383-5961

Fax (909) 383-6739.

All inquiries must include the contract number.

08-0H9304	
Inquiry No.	Inquiry/Response
1.0	<p>Question_1: Ref New Bridge Mounted Sign # S 4 - 5- Except for the sign elevation shown on Plan Sheet 42 o 75, there appears to be no details provided for the mounting, structural components etc. Will this information be provided to all bidders via an addendum?</p> <p>Response: Pending.</p>
2.0	<p>Question_2: Please confirm that new formed panels for signs S4-1 and S6-1 are to reuse existing Removable Sign Panel Frames.</p> <p>Response: Pending.</p>
3.0	<p>Question_3: Ref Special Provision Section 10-1.08-Please explain the dollar amounts shown after each of the materials which are to be considered for payment as Material on Hand.</p> <p>Response: Pending.</p>
4.0	<p>Question_4: Ref: Traffic Chart # 1, page 43 of Special Provisions. As now shown, chart #1 permits " .at least one through freeway lane open in direction of travel .." any where that there is a blank hour block. Is this correct?</p> <p>Response: Pending.</p>