

The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.

Send Contractor Inquiries via email to d8_pbi@dot.ca.gov

The mailing address is 655 2nd Street, San Bernardino, CA 92402.

Phone (909) 383-5961

Fax (909) 383-6739.

All inquiries must include the contract number.

08-0F1904	
Inquiry No.	Inquiry/Response
1.0	Question_1: Verify Conduits are to be PVC under Freeway? Response: Yes.
2.0	Question_2: Do Conduits Need to be in a Casing? Response: NO.
3.0	Question_3: Does Freeway Need to be Shut Down for Boring Operations? Response: NO.
4.0	Question_4: I was reading thru the specs and it doesn't specify what the liquidated damages are for this project. Response: Liquidated damages are found in section 8 of the Special Provisions (8-1.07 page 75 of 190 under AMENDMENTS).
5.0	Question_5: There are no specifications for the aboveground tanks. Is there a specific type of tank you want to use? Response: The specifications for the tanks are in Section 12-15.03, "Liquefied Petroleum Gas (LPG) System," of the special provisions, beginning on Page 68. Bid per the contract documents.