

The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.

Send Contractor Inquiries via email to [d8\\_pbi@dot.ca.gov](mailto:d8_pbi@dot.ca.gov)

The mailing address is 655 2<sup>nd</sup> Street, San Bernardino, CA 92402.

Phone (909) 383-5961

Fax (909) 383-6739.

**All inquiries must include the contract number.**

08-422204	
Inquiry No.	Inquiry/Response
1.0	<p>Question_1: The Liquidated Damages is completely left out of the specified section and is not referenced any place else. This information is required when requesting a bidder's bond.</p> <p><b>Response: The liquidated damages are part of the amendment section of the Special Provisions book. Please refer to page 76 of 214 of the amendment section.</b></p>
2.0	<p>Question_2: Specifications Section 4, page 8, "Beginning of Work, Time of Completion, and Liquidated Damages". The section does not say how much the Liquidated Damages are. Please clarify.</p> <p><b>Response: Calculation for liquidated damages is shown in the amendment. (See answer to Question # 1)</b></p>
3.0	<p>Question_3: What is the tentative starting date for this project?</p> <p><b>Response: Please refer to section 4 of the Special Provisions "BEGINNING OF WORK, TIME OF COMPLETION, AND LIQUIDATED DAMAGES".</b></p>
4.0	<p>Special_Provisions_Specific: Per Section 5-1.13, the Contractor shall notify the air pollution control district or air quality management district identified (South Coast AQMD) as required by the National Emission Standards for Hazardous Air Pollutants (NESHAP) at 40 CFR Part 61, Subpart M, and California Health and Safety Code section 39658 (b) (1) .</p> <p>Question_4: Does the Department expect the presence of asbestos in the existing bridge?</p> <p><b>Response: Pending</b></p>
4.1	<p>Question_1.2: It is our understanding that the State of California Department of Transportation will be listed as the generator of any hazardous material. Will a change order be issued for the removal and disposal of any hazardous material? **except for yellow thermo (LCP) **</p>

	<b>Response: Pending</b>
5.0	<p>Question_5: Please verify that a Joint Seal is required between the bridge and the asphalt roadway.</p> <p><b>Response: Pending</b></p>
6.0	<p>Question_6: Western Structures is bidding on the above referenced project and there is a 7% UDBe Contract Goal. There is nowhere that I can find to Query for UDBe's on your website. Could you please tell me how to find UDBe's to contact for invitations to bid? Will the use of DBE's be of any advantage? I look forward to hearing from you by reply soon. Thank you for your assistance.</p> <p><b>Response: Pending</b></p>
7.0	<p>Question_7: Will the Palo Verde Irrigation District shut off the water in the channel to allow for the installation of the temporary water diversion system? And if so, for what length of time?</p> <p><b>Response: Pending</b></p>
8.0	<p>Question_8: Based on field observations there is a Verizon communication line running through the bridge that is to be demolished. Will this line be taken out of service or must it somehow be protected in place, and if so under what bid item is this to be paid for?</p> <p><b>Response: Pending</b></p>
9.0	<p>Question_9: In reference to the pilings, can we use a larger steel casing than is shown on the plans? If this is acceptable, can the reinforcement as shown on plans be used in this larger casing? And specify if casing material must be new, or is used material acceptable?</p> <p><b>Response: Pending</b></p>
10.0	<p>Question_9: In reference to the casing installation, can the steel casing be driven into the ground without the alternative tip as shown, and then cleaned out (by drilling) to achieve the same result.</p> <p><b>Response: Pending</b></p>