

The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.

Send Contractor Inquiries via email to d8_pbi@dot.ca.gov

The mailing address is: 13970 Victoria Street, Fontana, CA 92336

Phone (909) 829-3331

Fax (909) 829-3347

All inquiries must include the contract number.

08-0J1404	
Inquiry No.	Inquiry/Response
1.0	<p>Question_1: I am unable to find a plan sheet for the CAS on this project. I am also unable to find a plan sheet for the permanent signs, resets, and relocates. Where can I find this information?</p> <p>Response: Pending</p>
2.0	<p>Question_2: Was the Bid Opening Date for this project postponed?</p> <p>Response: Yes, Addendum # 2 issued on May 16, 2012 postponed the Bid Opening Date for this project indefinitely. Another addendum will be forthcoming advising of the new Bid Opening Date and other changes.</p>
3.0	<p>Question_3: Does this project has a new Bid Opening Date?</p> <p>Response: Yes, Addendum # 3 issued on July 13, 2012 states that the new Bid Opening Date for this project will be July 26, 2012.</p>
4.0	<p>Question_4: PLAN SHEET E-6 CONTAINS CONTROLLER CABINET AND BBS FOUNDATION DETAILS FOR NEW INSTALLATION. HOWEVER PLAN SHEETS E-2 AND E-3 SEEM TO INDICATE OTHERWISE. PLEASE CLARIFY.</p> <p>Response: Pending</p>
5.0	<p>Question_5: PROPOSED EQUIPMENT AND POLE SCHEDULE ON PLAN SHEET E-4 DOES NOT CORRELATE WITH THE PLAN DRAWINGS ON PLAN SHEET E-3. PLEASE CLARIFY.</p> <p>Response: Pending</p>
6.0	<p>Question_6: DO THE OVERHEAD ELECTRICAL LINES POSE ANY INTERFERENCE WITH THE TRAFFIC SIGNAL WORK? NO SPECIAL NOTICE TO THE CONTRACTOR IS MADE ON THE PLANS.</p> <p>Response: Pending</p>