

The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.

Send Contractor Inquiries via email to d8_pbi@dot.ca.gov

The mailing address is 655 2nd Street, San Bernardino, CA 92402.

Phone (909) 383-5961

Fax (909) 383-6739.

All inquiries must include the contract number.

08-456004	
Inquiry No.	Inquiry/Response
1.0	Question_1: Are the cross sections available for the project. Response: Pending
2.0	Question_2: As the 556,000 M3 of Imported Borrow (Bid Item 50) and the over excavation will have a major impact on the cost of this project it is imperative that the bidders be able to make an accurate verification and assessment of this work. The contract plans show the original ground contours on the Layout Plans (sheets 11 through 27) and the finish grade contours on the Drainage and Contour Grading Plans (sheets 72 through 88). The only method that can utilize this information involves manually digitizing the two sets of contours and overlaying them. This does not provide for a suitable level of accuracy. Please provide either electronic files of the plan sheets (.dgn or .dwg) or cross sections for the project. Response: Pending