

The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.

Send Contractor Inquiries via email to d8_pbi@dot.ca.gov

The mailing address is 655 2nd Street, San Bernardino, CA 92402.

Phone (909) 383-4050

Fax (909) 383-6739.

All inquiries must include the contract number.

0A6404	
Inquiry No.	Inquiry/Response
1.0	<p>I would like to know the Job site address for the Demolish facilities -Construct Comfort station project. All I am aware of is...401 KM S Of California-Nevada state line at Valley Wells.</p> <p>Response: The location of this project is on I-15 (PM 161.2) between the interchange at Halloran Summit Road and the interchange at Cima Road. The project is at the Valley Wells Safety Roadside Rest Areas"</p>
2.0	<p>Would there be a mandatory job walk for subcontractors in abatement?</p> <p>Response: No mandatory job walk is required.</p>
3.0	<p>I cannot find the explanations of the following Legend Symbols on the following Electrical sheets E-1 thru E-8. (AB) (CB) (SC) (BC)</p> <p>Response: These are part of Standard Plans List ES-1A.</p>
4.0	<p>Sheet E-7 Shows 2 new 480V 3 -phase 200 amp Pedestal services. Sheet EE5 Shows a one line from pedestals to new SCE Service by pump house and refers to site plan. The site plan does not show a SCE service or give a distance to SCE service.</p> <p>Interpretation: Are we to stub out of new Pedestals and pick up to new SCE Service at a later date as a Change Order?</p> <p>Response: A Changer Order will be processed after the Contract is awarded to resolve the issue.</p>