

The responses to bidders' inquiries are provided for the bidders' convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given. Inquiries along with responses may be posted at the website only when the inquiries are submitted in any of the acceptable manner prescribed under the Notice to the Contractors and when the responses have already been communicated to the individual inquirers. Bidders' inquiries received over the phone must be followed-up and submitted in writing for an official response.

The Bidders' inquiries and Responses may be updated from time to time and bidders are enjoined to check the website regularly and immediately prior to the scheduled bid opening.

Caltrans District 8 Office is located at 464 W. Fourth Street, San Bernardino, CA 92401-1400.

Send Contractor Inquiries via email to d8_pbi@dot.ca.gov

The mailing address is 655 2nd Street, San Bernardino, CA 92402.

Phone (909) 383-5961

Fax (909) 383-6739.

All inquiries must include the contract number.

08-0F3504	
Inquiry No.	Inquiry/Response
1.0	<p>Question_1: Since existing picnic shelter has tested positive for Lead Based Paint, have you done any testing around the picnic shelters, in particular the drip line to see if the lead has impated soil? If not, how de we know if soil is clean or contaminated?</p> <p>Response: Pending</p>
2.0	<p>Question_2: Does the contract requires contractor to encapsulate the irrigation facility's roof near pump area? According to the Lead report, it is recommended by Secor!</p> <p>Response: Pending</p>
3.0	<p>Question_3: Please clarify where and what will be relocated for item number 12, under "Relocate Existing Irrigation Facility"?</p> <p>Do you have shower stall as an item to be built at this facility, rest area? You have provided drawings on page A0-3.4.</p> <p>Does the contractor install a new hot water heater? Currently there none, and you mentioned hot water insulations in your drawings.</p> <p>Response: Pending</p>
4.0	<p>Question_4: Please clarify where will be the new location of irrigation facility and what will be moved?</p> <p>Response: Pending</p>